

ECEN 615

Methods of Electric Power Systems Analysis

Lecture 12: August 14 2003 Blackout

Prof. Tom Overbye

Dept. of Electrical and Computer Engineering

Texas A&M University

overbye@tamu.edu



TEXAS A&M
UNIVERSITY


Announcements



- Homework 3 should be done before the first exam but need not be turned in
- Start reading Chapter 7 (the term reliability is now often used instead of security)
- First exam is in class on Thursday Oct 1
 - Distance learning students do not need to take the exam during the class period
 - Closed book, notes. One 8.5 by 11 inch notesheet and calculators allowed
 - Last's years exam is available in Canvas with answers

Blackouts

- Blackouts are costly, with some estimates of costs above \$100 billion per year.
- But blackouts are not created equal. Some are unavoidable due to large scale system damage (hurricanes, tornados and ice storms). Most are local, distribution issues.



Some Electric Grid Risks




FIGURE 3.1 Mapping of events that can cause disruption of power systems. The horizontal placement provides some indication of how much warning time there may be before the event. The vertical axis provides some indication of how long it may take to recover after the event. Lines provide a representation

The Real Cause of Most Blackouts!



But mostly only the small ones in the distribution system

Photo source: <http://save-the-squirrels.com>

High-Impact, Low-Frequency Events



- In order to enhance electric grid resiliency we need to consider the almost unthinkable events
- These include what the North American Electric Reliability Corporation (NERC) calls High-Impact, Low-Frequency Events (HILFs); others call them black sky days




Image Source: NERC, 2012

- Large-scale, potentially long duration blackouts
- HILFs identified by NERC were 1) a coordinated cyber, physical or blended attacks, 2) pandemics, 3) geomagnetic disturbances (GMDs), and 4) HEMPs

Avoidable Transmission Level Blackouts



- Many major blackouts can be prevented.
- Time frames of the blackouts, minutes to hours, allow for human intervention
 - Tokyo 1987 (20 minutes), WECC 1996 (six minutes), Eastern Interconnect 2003 (about an hour), Italy 2003 (25 minutes)
- And of course many are prevented, and hence do not make the news. For example, near voltage collapse in Delmarva Peninsula, 1999.

Going Back in Time



- The August 14th 2003 blackout is rapidly moving from being a “recent event” into history; yet it still has much to teach us.
- This talk is about the past and the future: what can we learn from the past to help us prepare for the future
 - But not so much about what are the immediate lessons from the Blackout since many recommendations have already been put into practice.
- The blackout final report is very readable and available by googling “August 14 2003 Blackout Report”

Blackout misery

50 million affected in Northeast and beyond as power grid fails

Transportation Many 'wait it out,' by air and land ■ 4A | Scenes Moms in labor, cars stuck in car washes ■ 5A | Impact Offices close, ATMs idle, cellphones jam ■ 1B




Brooklyn Bridge: Thousands of commuters in New York took to their feet Thursday evening after a major power outage hit the city and much of the Northeast.



In contrasting numbers, the August 14 2003 Blackout hit about 50 million people, while Hurricane Irene (2011) caused power outages affecting perhaps seven or eight million.

August 14, 2003 Hoax Image




This image was widely circulated immediately after the blackout, even appearing for a time on a DOE website. It was quickly shown to be a hoax.

What might immediately give it away?

Actual Before and After Images



My Favorite August 14, 2003 Cartoon



Causes of the Blackout



- Blackout Final Report listed four causes
 - FirstEnergy (FE) did not understand inadequacies of their system, particularly with respect to voltage instability.
 - Inadequate situational awareness by FE
 - FE failed to adequately manage their tree growth
 - Failure of the grid reliability organizations (primarily MISO) to provide effective diagnostic support
- Human/cyber interactions played a key role

We've Come Quite a Ways Since 2003



- Report included 46 recommendations, many of which have dramatically changed the operation of the interconnected power grid
 - Thirteen were focused on physical and cyber security
- Focus of talk is what can 8/14/03 teach us to help with the grid in 2020
- Need to keep in mind economic impact of 8/14/03 was above \$5 billion; yearly impact of blackouts could be above \$100 billion

First Energy Control Center, Recent (2013)



Image Source: www.wksu.org/news/story/365


My Involvement in Blackout Investigation



- I spend a lot of time talking to reporters on 8/14 to 8/16, before I knew what happened
- Tasked by DOE to do onsite visit to FE on 8/19 to 8/21 with Doug Wiegmann; did similar visit to MISO the next week.
- Did return visit in Oct
- Many folks played far larger roles; I was only involved extensively early on




Footprints of Reliability Coordinators in Midwest



August 13, 2003



- It is important to realize that immediately before the blackout few people thought the system was on the verge of a catastrophe.
- NERC 2003 Summer Assessment did not list Ohio as an area of particular concern



NERC 2003 Summer Assessment is available at <http://www.nerc.com/files/summer2003.pdf>

August 14, 2003: Pre-blackout (before 14:30 EDT)



- It had mostly been a normal summer day at First Energy
 - Most generation was available though the 883 MW Davis-Besse Nuclear unit was on a long-term outage
 - At 13:31 EDT the Eastlake 5 unit (a 597 MW plant on Lake Erie) tripped when the operator tried to up its reactive output, but this was not seen as a severe event
- It had been a busy day at MISO, with their reliability coordinators dealing with a relatively small outage in Indiana around noon
 - Their state estimator failed at 1215 EDT but no one knew this

Cinergy Bedford-Columbus 345 kV Line Tree Contact at 12:08 EDT



Trees were Finally “Trimmed” Two Months Later




At 14:27 EDT Star-South Canton 345 kV Line Trips and Recloses




- Star-South Canton is a tie between AEP & FE
- FE missed seeing this event since their alarms had hung several minutes earlier (14:14)
 - Line was back in service so it appeared normal in SCADA
 - FE IT folks knew about computer problems
- AEP called FE at 14:32 to check on event; FE says they saw nothing. A repeat call by AEP to FE at 15:19 also discusses event indicating ground current was detected.

Estimated High Level Voltage Profile at 15:00 EDT




Estimated Flows in Northeast Ohio at 15:00 EDT on August 14th 2003



Chamberlin-Harding
345 kV Line
trips at 15:05,
an event
that was
missed by
both FE and
MISO

Estimated Flows in Northeast Ohio at 15:06 EDT



Line Outage Distribution Factors (LODFs)



- LODFs are used to approximate the change in the flow on one line caused by the outage of a second line
 - typically they are only used to determine the change in the MW flow
 - LODFs are used extensively in real-time operations
 - LODFs are state-independent (calculated using dc power flow approximations) but do depend on the assumed network topology
 - Below value tells change of real power flow on line ℓ for the assumed outage of line k ; f_k^0 is (obviously) pre-contingent

$$\Delta f_\ell = d_{\ell,k} f_k^0$$

Flowgates



- The real-time loading of the power grid is accessed via “flowgates”
- A flowgate “flow” is the real power flow on one or more transmission element for either base case conditions or a single contingency
 - contingent flows are determined using LODFs
- Flowgates are used as proxies for other types of limits, such as voltage or stability limits
- Flowgates are calculated using a spreadsheet

Flowgate #2265




- Flowgate 2265 monitors the flow on FE's Star-Juniper 345 kV line for contingent loss of the Hanna-Juniper 345 Line
 - normally the LODF for this flowgate is 0.361
 - flowgate has a limit of 1080 MW
 - at 15:05 EDT the flow was 517 MW on Star-Juniper, 1004 MW on Hanna-Juniper, giving a flowgate value of $520 + 0.361 * 1007 = 884$ (82%)
 - Chamberlin-Harding 345 opened at 15:05; FE and MISO all missed seeing this

The Bad LODF that Maybe Blacked Out the Northeast




- At 15:06 EDT (after loss of Chamberlin-Harding 345) #2265 has an incorrect value because its LODF was not automatically updated.
 - Value should be $633 + 0.463 * 1174 = 1176$ (109%)
 - Value was $633 + 0.361 * 1174 = 1057$ (98%)
- At 15:32 the flowgate's contingent line opened, causing the flowgate to again show the correct value, about 107%

Flows at 15:33 EDT



Estimated Northeast Ohio 138 kV Voltage Contour: 15:33 EDT




IT Issues




- MISO RCs had gotten many hundreds of “alarms”
- Contingency analysis results were giving pages of violations.
- SE would fail because of severe system stress
- Inadequate procedures for dealing with SE failure.
- FE control center would get “many phone calls;” information was not effectively shared.


Estimated Flows in Northeast Ohio at 15:46 EDT on August 14th 2003




Estimated Northeast Ohio 138 kV Voltage Contour: 15:46 EDT



Estimated Flows in Northeast Ohio at 16:05 EDT on August 14th 2003



Estimated Northeast Ohio 138 kV Voltage Contour: 16:05 EDT



Path to Cleveland Blocked after Loss of Sammis-Star 16:05:57





Image Source: August 14 2003 Blackout Final Report

345 kV Lines Trip Across Ohio to West at 16:09



Generation Trips 16:09:08 – 16:10:27




Image Source: August 14 2003 Blackout Final Report

Parts of Ohio/Michigan Served Only from Ontario after 16:10:37




Image Source: August 14 2003 Blackout Final Report

Major Power Reversal: 16:10:38





Image Source: August 14 2003 Blackout Final Report

Ontario/Michigan Interface Flows and Voltage



Ties from PJM to New York Open: 16:10:44 (North Ohio Black)





Image Source: August 14 2003 Blackout Final Report

System Islands Break Up and Collapse: 16:10-16:13



Are DC LODFs Accurate?

August 14th Crash Test



- Here are some results from August 14th

Time	Contingency	Element	LODF	Δ MW (pred)	Δ MW (act)
15:05	Chamberlin-Harding 345	Hanna-Juniper 345	0.362	179	176
15:32	Hanna-Juniper 345	Star-Juniper 345	0.465	545	527
15:46	CantonCentral-Cloverdale 138	Sammis-Star 345	0.164	48	54
15:46	same	Cloverdale-Star 138	0.234	68	64
16:06	Sammis-Star 345 Star-Urban 138 W.Canton-Dale 138	Star-Juniper 345	numerous	517	676
16:06	same	Ashtabula-Perry 345	numerous	319	408

The Results are Actually Quite Good!



- The initial LODF values were accurate to within a few percent
- Even after more than a dozen contingencies, with many voltages well below 0.9 pu, the purely DC LODF analysis was giving fairly good (with 25%) results

What Could Have Occurred on August 14th?



- With 20/20 Hindsight the blackout probably could have been prevented. A smarter grid might have provided the necessary situational awareness, and/or provided the dynamic load reduction necessary to keep the system from cascading.
- But key issues are 1) which grid improvement costs are cost justified, and 2) what are we missing?

How Could a Smart Grid Help?



- Under frequency and under voltage relays can provide quick reduction in the load, but they need to be smart enough to make the right decision
- Dynamic pricing (LMPs) can help customers make economic decisions, but they depend upon a variety of “advanced applications” in order to calculate the LMPs: state estimation converging to provide the model for the SCOPF

Some Thoughts on Current Needs



- The data used in the models for interconnect wide studies still have significant problems
- In US we have 100 GW of wind resources, but do not always have adequate models for transient stability studies; there are also potential low voltage ride through issues with solar
- Power grid is rapidly changing which can result in some operational “surprises”
- High impact, low frequency events are also a concern
- We need people with a deep knowledge of power systems and (fill in the blank)!